



- 1) BRICKWORK, BLOCKWORK OR CONCRETE**
- 2) CEMENT MORTAR POINTING**
- 3) 25MM X 25MM CHASE**
- 4) MIN. 150MM HIGH 13MM TWO COAT SKIRTING WITH ANGLE FILLET**
- 5) 25MM TWO-COAT MASTIC ASPHALT. 1ST COAT ROOFING GRADE. 2ND COAT ROOFING GRADE WITH 10-15% ADDITIONAL GRIT**
- 6) SEPARATING MEMBRANE IF REQUIRED**
- 7) CEMENTITIOUS SCREED LAID TO FALLS IF REQUIRED**
- 8) CONCRETE OR SIMILAR BASE**

## FLOORING

- 1) CONCRETE OR SIMILAR DECK**
- 2) APPROPRIATE THICKNESS OF FLOORING GRADE MASTIC ASPHALT**
- 3) 13MM ONE-COAT ROOFING GRADE MASTIC ASPHALT**
- 4) 50MM MINIMUM BEARING WIDTH**
- 5) NOT THICKER THAN FLOORING GRADE MASTIC ASPHALT**
- 6) INCREASE THICKNESS OF WATERPROOFING OR USE BITUMINIOUS PACKING IF THINNER THAN PAVING GRADE ASPHALT**
- 7) 20MM TWO-COAT ROOFING GRADE MASTIC ASPHALT**
- 8) 13MM TWO-COAT ROOFING GRADE MASTIC ASPHALT SKIRTING WITH FILLET**
- 9) CAST IRON OR OTHER SUITABLE CHANNEL GRATING (FRAMES, IF USED SHOULD BE WITHOUT FIXING LUGS WHICH MIGHT PIERCE THE ROOFING GRADE ASPHALT)**

